



Jackson Hole Fire/EMS Operations Manual

Developed by: Rusty Palmer
Rusty Palmer, Deputy Chief

Approved by: Steve Mooney
Teton Emergency Responders Association

Approved by: Carlos Rodriguez
Carlos Rodriguez, Chief

Approved by: George Landa
Emergency Services Council

Title: **Hydrant Painting**
Division: 12
Article: 6
Revised: 10/01/04
Pages: 1

PURPOSE

SECTION I – HYDRANT COLOR

All hydrants within the limits of the Town of Jackson, or any hydrant connected to the Town of Jackson water system shall be identified by color, as follows:

1. **RED:** Hydrants flowing up to 500 gallons per minute.
2. **ORANGE:** Hydrants flowing 501 – 1000 gallons per minute.
3. **GREEN:** Hydrants flowing 1001 – 1500 gallons per minute.
4. **BLUE:** Hydrants flowing greater than 1500 gallons per minute.

All portions of the hydrant above the grade flange shall be painted the appropriate color, based upon its flow rate.

All hydrants shall be numbered by tag or stamp with numbers corresponding to the department's numbering process.